

**Date: 27.11.2024****AMENDMENT – 1****Tender Ref. No- JIL-YEW/NIT/2024/112 Dated 18.11.2024 for****Design & Construction of Sewage Treatment Plant (STP) of capacity 100 KLD & Effluent Treatment Plant (ETP) of capacity 50 KLD for Facility at km 35 LHS on Yamuna Expressway.****Subject: Amendment in Tender Documents**

With reference to the above-referred tender the following amendments are being made.

1. Time allowed for completion has been **revised to 10 months** from 6 months. (Ref: Memorandum, Annexure -1 of Volume -I)
2. Some of the makes and specifications has been revised in Volume-II (BOQ), which are as under:

S.No	Description	Details of size and specifications (As per document)	Details of size and specifications (Revised)
<u>Annexure -III</u>			
2	Air Blower		
	Capacity	100-120 m3/hr at 0.25 kg/cm2	100-120 m3/hr at 0.5 kg/cm2
3	Air diffusers		
	Make	Bobkay / Airfin/ MM Aqua	Airfin/ MM Aqua/Rehau
15	Bio Media for MBBR Tanks & Tube Settler Tank		
	Make of Bio-Media	BOBKEY / MM AQUA /TUBEDEK /BIODEK	MM AQUA /BIODEK/ COOLDEK
16	Electrical Panels + Cabling		
	Complete Electricals, Instrumentation, Control Panel with PLC, HMI System & Cabling as suitable to run all power drives	CRCS Powder quoted Encloser. Cable: Polycab, Fenolex, Havells, Devices: L&T, Siemens, Schneider	CRCA Powder quoted Encloser. Cable: Polycab, Fenolex, Havells, Devices: L&T, Siemens, Schneider * Panels must be CPRI Tested/ Certified
17	INSTRUMENTATION EQUIPMENTS AND LABORATORY EQUIPMENTS & APPARATUS		
A	Flow Meter	Adept/ Electronet	Adept/ Electronet / Aster
<u>BOQ</u>			
E	MEP Works for 50 KLD ETP		
	21	Flocculation Agitator with gear box (capacity 0.5 hp with suitable rpm, MOC- SS 304) Make : HELP / Equivalent.	Flocculation Agitator with gear box (capacity min. 1 hp with suitable rpm, MOC- SS 304) Make : HELP / Equivalent.
	22	Flash Mixer Tank (Capacity 1500 Litre, MOC-M.S.E.P) with all accessories including High speed Agitator (capacity 0.5 hp with suitable rpm, MOC- SS 304) with worm gear complete	Flash Mixer Tank (Capacity 1500 Litre, MOC-M.S.E.P) with all accessories including High speed Agitator (capacity min. 1 hp with suitable rpm, MOC- SS 304) with worm gear complete

3. Last date & time of submission of tender in hard copies / through email have been extended up to 07.12.2024 by 7.00 PM (IST).
4. Date & Time of Opening of technical Tender shall be at 09.12.2024 at 4.30 PM.
5. Except as mentioned above, the terms and conditions of the tender remains same, Ref No. JIL/YEW/NIT/2024/112, dated 18.11.2024.